

MANCHESTER LEAD TESTING RESULTS

(PPM)

<u>Sample ID</u>	<u>Sample Type*</u>	<u>2014</u>	<u>2011</u>	<u>2008</u>	<u>2005</u>	<u>LEAD MAXIMUM CONTAMINANT LEVEL</u>
LC001	TIER 1	<0.001	<0.001	<0.001	<0.001	<u>0.015 PPM</u>
LC002	TIER 1		<0.001	0.006	<0.001	
LC003	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC004	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC005	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC006	TIER 1	<0.001	<0.001	<0.001	0.003	
LC007	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC008	TIER 1	0.010	<0.001	<0.001	<0.001	
LC009	TIER 1	0.010	<0.001	0.006	<0.001	
LC010	TIER 1	<0.001	<0.001	0.003	<0.001	
LC011	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC012	TIER 1	<0.001	0.001	0.006		
LC013	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC014	TIER 1	<0.001	<0.001		<0.001	
LC015	TIER 1	<0.001		<0.001	0.001	
LC017	TIER 1		<0.001	0.001	<0.001	
LC018	TIER 1	0.005	<0.001	0.005	<0.001	
LC019	TIER 1	<0.001		<0.001	<0.001	
LC020	TIER 1	<0.001	<0.001	0.001	<0.001	
LC021	TIER 1		0.002	<0.001		
LC022	TIER 1	0.005	<0.001	<0.001	<0.001	
LC023	TIER 1	<0.001	0.004	0.005	<0.001	
LC025	TIER 1		0.002	<0.001	<0.001	
LC026	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC027	TIER 1	<0.001	0.005	0.001	<0.001	
LC030	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC031	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC032	TIER 1		<0.001	<0.001	<0.001	
LC033	TIER 1	<0.001	<0.001	<0.001	0.005	
LC034	TIER 1	<0.001	0.003	<0.001	<0.001	
LC035	TIER 1	<0.001		<0.001	<0.001	
LC036	TIER 1		0.003	<0.001	<0.001	
LC037	TIER 1	<0.001	<0.001	<0.001	0.004	
LC038	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC039	TIER 1	<0.001	<0.001	0.001	<0.001	
LC040	TIER 1	0.004	0.002	<0.001	<0.001	
LC041	TIER 1	<0.001	0.002	0.001	<0.001	
LC044	TIER 1	<0.001	<0.001	0.001		
LC046	TIER 1	<0.001	<0.001	<0.001	<0.001	
LC054	TIER 1	<0.001	0.002	0.001	<0.001	
LC071	TIER 1		0.002	<0.001	<0.001	

Tier 1*single family homes
that contain copper pipes
and lead solder installed
after 1982; or contain lead
pipes ;or are served by a lead
service line